



General Notes:

1. Water connection to be located in the left or right corner of each lot a maximum of 500 mm from the side boundary
2. Any pressure limiting valves required to be installed under the requirements of AS3500 are to be installed downstream of the meter
3. All meters and meter tails are to be supplied by Bega Valley Shire Council
4. TPFNR (brass), tapping band (brass), and connectors must be rated to a minimum PN16, or higher as per design plans and comply with AS/NZS 4020.
5. All valves must be resilient seated, clockwise closing to AS 1628 with 316 stainless steel bolts and washers.
6. 1 metre of Class A copper must be installed underground with above ground meter installations
7. All fittings to PE pipe are to be electrofusion.



REV	Description	Date
A	Residential water connection	07/20



Project	4992
Description	Residential water connection
Plan No.	4992